

Summary of Available Windstorm Test Reports (11-10-2011)

3M Window Film	Attachment System	Glass Type	Glass Size	Missile Level	Design Pressure (psf)	Test Report Number & Date Performed	Results
Ultra S400	Impact Protection Adhesive	Annealed - 1/4" Monolithic	48" x 60"	A	+/- 50	80516.01-201-44 2/5/2008	PASS
Ultra S400	Impact Protection Profile -- BP700	Tempered - 1/4" Monolithic	48" x 60"	A	+/- 50	84503.02-201-44 7/16/2008	PASS
Ultra S400	Impact Protection Profile -- BP950	Tempered - 1/4" Monolithic	48" x 60"	A	+/- 50	82921.01-201-44 05/12/2008	PASS
Ultra S600	Impact Protection Adhesive	Annealed - 1/4" Monolithic	48" x 60"	C	+/- 50	85573.02-201-44 8/20/2008	PASS
Ultra S600	Impact Protection Adhesive	Tempered - 1/4" Monolithic	48" x 60"	C	+/- 50	85573.01-201-44 8/20/2008	PASS
Ultra S600	Impact Protection Profile -- BP950	Tempered - 1/4" Monolithic	48" x 60"	C	+/- 50	84503.01-201-44 7/16/2008	PASS
Safety S140	Impact Protection Adhesive	Tempered - 1/4" Monolithic	48" x 60"	C	+/- 50	75472.01-201-44 08/02/2007	PASS
Affinity S65	Impact Protection Adhesive	Tempered - 1/4" Monolithic	45" x 93"	C	+/- 50	A4055.01-201-44 10/12/2010	PASS
Ultra S400	Impact Protection Adhesive	Tempered - 1/4" Monolithic	45" x 93"	C	+/- 70	A4056.01-201-44 10/12/2010	PASS **
Ultra Prestige PR-S50	Impact Protection Adhesive	Tempered - 1/4" Monolithic	45" x 93"	C	+/- 50	A4057.01-201-44 10/12/2010	PASS

** Passed pressure cycling at 70 psf DP after passing complete loading sequence at 50 psf DP