

# Glass and Glazing Federation

Certifies that

*3M Scotchshield™*


Certificate No: *TC 0182*

3M Scotchshield™ SCLARL400 has  
passed Class 2B2 of BS EN 12600 'Glass in Building – Pendulum  
Test – Impact Test Method and Classification  
for Flat Glass' on 6mm Float Glass

Tested at Wintech Engineering Ltd, UKAS accredited Test Laboratory, No.2223

Issued: *27 May 2002*

Chief Executive:



N Rees

Testing Officer:



S H Rice



Glass and Glazing Federation

Glass and Glazing Federation  
44 – 48 Borough High Street  
London  
SE1 1XB  
Tel: 020 7207 5872  
Fax: 020 7357 7458

Test Facility:  
WİNTECH Engineering Ltd  
Halesfield 2  
Telford TF7 4QH  
Tel: 01952 586580  
Fax: 01952 586585